



NOTES:

1. POLE MOUNTED POWER SUPPLY DISCONNECT SHALL BE SQUARE 'D' CQO TYPE 3R WEATHERPROOF OR REVIEWED EQUIVALENT.
2. GROUND MOUNTED PEDESTAL SHALL BE PEDESTAL SOLUTIONS INC. SL42 NON-METERED WITH PRECAST CONCRETE BASE OR REVIEWED EQUIVALENT.
3. METERED PEDESTALS FOR RECEPTACLE LOADS SHALL BE PEDESTAL SOLUTIONS INC. SLM42 OR REVIEWED EQUIVALENT.

1	REVISED TOWN LOGO	TOI	APRIL 2015
NO.	REVISIONS	APRD	DATE



ROADWAY LIGHTING
DISTRIBUTION
SINGLE LINE DIAGRAM

METRIC
ALL DIMENSIONS IN mm
UNLESS OTHERWISE NOTED

**TOISD
1004**

DRAWN: D.S.L.

APRD: O.P.M.

SCALE: N.T.S.

DATE: JUNE 2011