

- 8. TELECOMMUNICATIONS PEDESTALS ARE TO BE LOCATED ON THE NON-OPENING SIDE OF A TRANSFORMER OR SWITCH GEAR
- 9. ALL SIDEWALK IS TO BE CONSTRUCTED ON A PROPERLY COMPACTED FOUNDATION OF A MINIMUM OF 150mm OF GRANULAR 'A'.
- 10. DESIGNER TO CONTACT TOWN BEFORE INITIATING DESIGN OF UTILITIES TO CONFIRM USE OF I.T. DUCTS WITHIN THE JOINT USE UTILITY TRENCH.



WINDOW STREET METRIC 20.0m ROAD ALLOWANCE ALL DIMENSIONS IN mm 4. REVISED NOTES **SEPT 2025** UNLESS OTHERWISE NOTED 8.5m PAVEMENT WIDTH 3. TO REFLECT TOWN STANDARDS TOL MAY 2019 2. TO REFLECT TOWN STANDARDS **APRIL 2018** TOI **TOISD** DRAWN: APR'D: 1. REVISED NOTES AND WATER SERVICES TOI **APRIL 2015** 202 SCALE: N.T.S. REVISIONS APR'D DATE: JUNE 2011 NO. DATE