



NOTES

1. DEPTH OF WATERMAIN & SEWERS AS PER TOWN STANDARD DESIGN CRITERIA.
2. WHEN POWER AND COMMUNICATION DUCTS AND CABLES ENCOUNTER HYDRANTS AND VALVES, THE CABLE IS TO LOOP BEHIND THE HYDRANT AWAY FROM THE WATERMAIN.
3. PAVEMENT STRUCTURE TO BE INSTALLED IN ACCORDANCE WITH SECTION 2.2 PAVEMENT DESIGN. THE FOLLOWING IS A MINIMUM PAVEMENT STRUCTURE AND MAY BE GREATER IN ACCORDANCE WITH GEOTECHNICAL REPORT:
 - 40mm SURFACE COURSE ASPHALT.
 - 60mm BASE COURSE ASPHALT.
 - 150mm GRANULAR "A".
 - 400mm GRANULAR "B".
4. THE BOULEVARDS AND DITCHES REQUIRE A MINIMUM OF 300mm OF TOPSOIL & NURSERY SOD.
5. LOCALIZED GRADING AROUND TRANSFORMER TO MAINTAIN A LEVEL TRANSFORMER PLATFORM.
6. DITCH DEPTH AS PER DESIGN
7. HYDRANT WALKWAY AND CULVERT REQUIRED UNLESS OTHERWISE DIRECTED BY THE TOWN.
8. TRANSFORMER ACCESS AND CULVERT REQUIRED UNLESS OTHERWISE DIRECTED BY THE TOWN.
9. TELECOMMUNICATIONS PEDESTALS ARE TO BE LOCATED ON THE NON-OPENING SIDE OF A TRANSFORMER OR SWITCH GEAR.



RURAL LOCAL ROAD 20.0m ROAD ALLOWANCE 7.0m PAVEMENT WIDTH

DRAWN:

APR'D:

SCALE: N.T.S.

DATE: JUNE 2011

3	REVISED NOTES	TOI	SEPT 2025
2	REVISED NOTES	TOI	APRIL 2018
1	REVISED NOTES AND WATER SERVICES	TOI	APRIL 2015
NO.	REVISIONS	APR'D	DATE

METRIC
ALL DIMENSIONS IN mm
UNLESS OTHERWISE NOTED

TOISD
207