



#### NOTES

1. DEPTH OF WATERMAIN & SEWERS AS PER TOWN STANDARD DESIGN CRITERIA.
2. WHEN POWER AND COMMUNICATION DUCTS AND CABLES ENCOUNTER HYDRANTS AND VALVES, THE CABLE IS TO LOOP BEHIND THE HYDRANT AWAY FROM THE WATERMAIN.
3. PAVEMENT STRUCTURE TO BE INSTALLED IN ACCORDANCE WITH SECTION 2.2 PAVEMENT DESIGN. THE FOLLOWING IS A MINIMUM PAVEMENT STRUCTURE AND MAY BE GREATER IN ACCORDANCE WITH GEOTECHNICAL REPORT:  
 40mm SURFACE COURSE ASPHALT.  
 110mm BASE COURSE ASPHALT (TO BE PLACED IN 2 LIFTS - 50mm and 60mm).  
 150mm GRANULAR "A".  
 500mm GRANULAR "B".
4. THE BOULEVARDS AND DITCHES REQUIRE A MINIMUM OF 300mm OF TOPSOIL & NURSERY SOD.
5. LOCALIZED GRADING AROUND TRANSFORMER TO MAINTAIN A LEVEL TRANSFORMER PLATFORM.
6. DITCH DEPTH AS PER DESIGN
7. HYDRANT WALKWAY AND CULVERT REQUIRED UNLESS OTHERWISE DIRECTED BY THE TOWN.
8. TRANSFORMER ACCESS AND CULVERT REQUIRED UNLESS OTHERWISE DIRECTED BY THE TOWN.
9. TELECOMMUNICATIONS PEDESTALS ARE TO BE LOCATED ON THE NON-OPENING SIDE OF A TRANSFORMER OR SWITCH GEAR.



RURAL INDUSTRIAL ROAD  
26.0m ROAD ALLOWANCE  
10.0m PAVEMENT WIDTH

DRAWN:

APR'D:

SCALE: N.T.S.

DATE: JUNE 2011

3	REVISED NOTES & PAVEMENT WIDTH	TOI	SEPT 2025
2	REVISED NOTES	TOI	APRIL 2018
1	REVISED NOTES AND WATER SERVICES	TOI	APRIL 2015
NO.	REVISIONS	APR'D	DATE

**METRIC**  
ALL DIMENSIONS IN mm  
UNLESS OTHERWISE NOTED

**TOISD**  
**208**