



NOTES

1. ALL MECHANICAL JOINTS TO BE RESTRAINED.
2. PROVIDE BOND BREAKER BETWEEN CONCRETE AND FITTINGS.
3. REFER TO TOWN DESIGN STANDARDS FOR APPROVED MATERIALS.
4. REFER TO TOWN DESIGN STANDARDS FOR ADDITIONAL REQUIREMENTS IF PRIVATE FIRE HYDRANTS ARE BEING PROVIDED.
5. FIRE LINE AND DOMESTIC SERVICE TO BE FULLY RESTRAINED FROM WATERMAIN TO PROPERTY LINE.



STANDARD FIRE LINE AND SERVICE CONNECTION

DRAWN: TOI

APR'D:

SCALE: N.T.S.

DATE: JUNE 2011

3.	ADDED NOTE 5 & GATE VALVE	TOI	SEPT 2025
2.	ADDED NOTE 4	TOI	FEB 2022
1.	REVISED TOWN LOGO	TOI	APRIL 2015
NO.	REVISIONS	APR'D	DATE

METRIC
ALL DIMENSIONS IN mm
UNLESS OTHERWISE NOTED

**TOISD
704**