

- INCOMING PIPE
- METERS MAY BE INSTALLED VERTICAL IN EXISTING DWELLINGS (IE. NOT NEW SUBDIVISIONS). SUBJECT TO TOWN WATER DEPARTMENT APPROVAL
- METERS AND REMOTE TOUCHPAD SUPPLIED BY TOWN WATER DEPARTMENT.
- REMOTE TOUCHPAD WILL BE ON A SIDE WALL WITHIN 3m (10 FEET) OFF THE FRONT WALL OF THE DWELLING.
- METER SUPPORT SHALL BE REQUIRED. PIPE SUPPORTS TO CONFORM TO PART 7 OF THE OBC.
- ANGLE BALL METER VALVE SUPPLIED BY TOWN WATER DEPARTMENT.
- DUAL CHECK VALVE, BACKFLOW PREVENTER OR APPROVED EQUAL.
- WATER METER TO BE A MINIMUM 600mm (24") FROM ANY OBJECT.
- WATER METER TO BE IN A HEATED AREA WHICH IS ACCESSIBLE FROM INSIDE THE HOUSE.
- EXPANSION TANK REQUIRED BEYOND THE DUAL CHECK VALE, AS PER PART 7 OF THE OBC.

6.	REVISED NOTES & MIN. DRAIN DIST.	TOI	SEPT 2025
5.	ADD NOTE 11	TOI	MAY 2022
4.	REVISE SUPPLY LINE SIZE	TOI	MAY 2021
3.	TO REFLECT TOWN STANDARDS	TOI	MAY 2019
2.	TO REFLECT TOWN STANDARDS	TOI	APRIL 2018
1.	REVISED TOWN LOGO	TOI	APRIL 2015
NO.	REVISIONS	APR'D	DATE



TYPICAL METER INSTALLATION (19mm TO 25mm)

METRIC ALL DIMENSIONS IN mm UNLESS OTHERWISE NOTED

DRAWN:	APR'D:
SCALE: N.T.S.	DATE: JUNE 2011

TOISD 706