

- All dimensions are in millimetres unless otherwise shown.
- All joints to be mechanically restrained, including joints on existing watermain.
- Length of water pipe to be centred at the point of crossing so that the joints will be equidistant and as far as possible from the sewer.
- 5. Insulation required for storm sewer or culvert crossing.



	WATERMAIN LOWERING						METRIC ALL DIMENSIONS IN TRITE UNLESSE OTHERWISE NOTED TOISD
	DRAWN: TOI	APR'D:					727
	SCALE: N.T.S.	DATE: MAY 2025	NO.	REVISIONS	APR'D	DATE	121